

# Town Of Alma 2012 Drinking Water Consumer Confidence Report (CCR) For Calendar Year 2011

*Public Water System ID: CO0147001*

**Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca.**

We are pleased to present to you this year's water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water.

Please contact **Nick Radtke** at **719-833-2712** with any questions about the Drinking Water Consumer Confidence Report or for public participation opportunities that may affect the water quality.

### General Information

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791) or by visiting <http://water.epa.gov/drink/contaminants>. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and microbiological contaminants call the EPA Safe Drinking Water Hotline at (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides**, that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- Radioactive contaminants**, that can be naturally occurring or be the result of oil and gas production and mining activities.
- Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

### Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems (especially for pregnant women and young children). It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home's plumbing. If you are concerned about lead in your water, you may wish to have your water tested. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Additional information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or by visiting <http://www.epa.gov/safewater/lead>.

### Our Water Source(s)

The Colorado  
and Environ

Source Water Assessment Report for our water supply. You may obtain a copy of the report by visiting <http://www.cdphe.state.co.us/wq/sw/swap> clicking on **Park County** and selecting **147001; Alma Town Of** or by contacting **Nancy Comer** at **719-833-2712**. For general information about visit <http://www.cdphe.state.co.us/wq/sw/swaphom.html>.

Potential sources of contamination in our source water area come from: Existing and Abandoned Mine Sites, Commercial and Industrial Transportation, Residential, Forest, Septic Systems, and Road Miles, Pet Waste, and Illegal Dumping of Grow Media.

The Source Water Assessment Report provides a screening-level evaluation of potential contamination that **could** occur. It **does not** mean that the occur. We can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan. Please contact **Tim Zingler** at **719-833-2712** to learn more about what you can do to help protect your drinking water sources, any questions about the Confidence Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the quality water we deliver to you every day.

Water Sources			
Source	Source Type	Water Type	
EMERGENCY INF GAL ON BUCKSKIN CREEK	Infiltration Gallery	Surface Water	
MAIN INF GAL ON BUCKSKIN CREEK	Intake	Surface Water	

## Detected Contaminant(s)

Town Of Alma routinely monitors for contaminants in your drinking water according to Federal and State laws. The following detections found in the period of January 1 to December 31, 2011 unless otherwise noted. The State of Colorado requires us to monitor for contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. The distribution system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be subject to annual fluctuations. Violations and Formal Enforcement Actions, if any, are reported in the next section of this report. Any additional information regarding violations is in the next section of this report.

**Note:** Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section, that means we did not detect any contaminants in the last round of monitoring.

Lead and Copper Sampled in the Distribution System						
Contaminant Name	Monitoring Period	90th Percentile	Number of Samples	Unit of Measure	Action Level	Sample Sites Above Action Level
COPPER	01/01/2008 to 12/31/2010	0.71	5	ppm	1.3	0
LEAD	01/01/2008 to 12/31/2010	3	5	ppb	15	0

Disinfection By Products (TTHMs, HAA5, and Chlorite) Sampled in the Distribution System								
Contaminant Name	Year	Average of Individual Samples	Range of Individual Samples (Lowest - Highest)	Number of Samples	Unit of Measure	MCL	MCLG	Violations
TOTAL HALOACETIC ACIDS (HAA5)	2011	17.24	17.24 - 17.24	1	ppb	60	N/A	0
TTHM	2011	15.5	15.5 - 15.5	1	ppb	80	N/A	0

Turbidity Sampled at the Entry Point to the Distribution System				
Contaminant Name	Sample Date	Level Found	TT Requirement	TT Violations
TURBIDITY	Date:	Highest single measurement: 0.99 NTU	Maximum 5 NTU for any single measurement	No
TURBIDITY	Month: December, 2011	Lowest monthly percentage of samples meeting TT requirement for our technology: 100%	In any month, at least 95% of samples must be less than 1.0 NTU	No

Regulated Contaminants Sampled at the Entry Point to the Distribution System								
Contaminant Name	Year	Average of Individual Samples	Range of Individual Samples (Lowest - Highest)	Number of Samples	Unit of Measure	MCL	MCLG	MCL Violation?
BARIUM	2011	0.044	0.044 - 0.044	1	ppm	2	2	No
CHROMIUM	2011	1	1 - 1	1	ppb	100	100	No
FLUORIDE	2011	0.38	0.38 - 0.38	1	ppm	4	4	No
NITRATE	2011	0.24	0.24 - 0.24	1	ppm	10	10	No

Secondary Contaminants**					
Contaminant Name	Year	Average of Individual Samples	Range of Individual Samples (Lowest - Highest)	Number of Samples	Unit of Measure
NICKEL	2011	0.001	0.001 - 0.001	1	ppm
SODIUM	2011	1.1	1.1 - 1.1	1	ppm

\*\*Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste or odor) in drinking water. EPA recommends these standards but does not require water systems to comply.

<b><u>Terms and Abbreviations</u></b>		
<b><u>Term</u></b>	<b><u>Abbreviation</u></b>	<b><u>Definition</u></b>
Maximum Contaminant Level Goal	MCLG	The 'Goal' is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Contaminant Level	MCL	The 'Maximum Allowed' is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Treatment Technique	TT	A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
Action Level	AL	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Maximum Residual Disinfectant Level Goal	MRDLG	The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Maximum Residual Disinfectant Level	MRDL	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Average of Individual Samples	No Abbreviation	The typical value. Mathematically it is the sum of values divided by the number of samples.
Range of Individual Samples	No Abbreviation	The lowest value to the highest value.
Number of Samples	No Abbreviation	The number or count of values.
Gross Alpha, Including RA, Excluding RN & U	No Abbreviation	This is the gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222 and uranium.
Variance and Exemptions	V/E	Department permission not to meet an MCL or a treatment technique under certain conditions.
Parts per million = Milligrams per liter	ppm = mg/L	One part per million corresponds to one minute in two years or a single penny in \$10,000.
Parts per billion = Micrograms per liter	ppb = ug/L	One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
Parts per trillion = Nanograms per liter	ppt = nanograms/L	One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
Parts per quadrillion = Picograms per liter	ppq = picograms/L	One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.
Picocuries per liter	pCi/L	Picocuries per liter is a measure of the radioactivity in water.
Nephelometric Turbidity Unit	NTU	Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
Not Applicable	N/A	Does Not Apply.
Violation	No Abbreviation	A failure to meet a Colorado Primary Drinking Water Regulation.
Formal Enforcement Action	No Abbreviation	An escalated action taken by the State (due to the number and/or severity of violations) to bring a non-compliant water system back into compliance by a certain time, with an enforceable consequence if the schedule is not met.

### **Violation(s) and Formal Enforcement Action(s)**

#### **Violations**

**No Violations to Report**

#### **Formal Enforcement Actions**

**No Formal Enforcement Actions to Report**